

Metropolitan Nashville - Davidson County

Stormwater Pond Inspections and Maintenance Checklist

Site Name: _____ Owner Change since last inspection? Y N

Location: _____

Owner Name: _____

Address _____ Phone Number _____

Site Status: _____

Date: _____ Time: _____ Site conditions: _____

Stormwater Pond Type: Wet Pond Wet ED Pond Micropool Pond Multiple Pond System
 Dry Pond

Inspection Frequency Key: A=annual(required); M=monthly(recommended); S=after major storms(recommended)

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
Embankment and Emergency Spillway				
Vegetation healthy?	A/S			
Erosion on embankment?	A/S			
Animal burrows in embankment?	A/S			
Cracking, sliding, bulging of dam?	A/S			
Drains blocked or not functioning?	A/S			
Leaks or seeps on embankment?	A/S			
Slope protection failure functional?	A/S			
Emergency spillway obstructed?	A/S			
Erosion in/around emergency spillway?	A/S			
Other (describe)	A/S			
Riser and Principal Spillway				(describe type: concrete pipe, slotted weir, channel, etc.)
Low-flow orifice functional?	A/S			
Trash rack (Debris removal needed? Corrosion noted?)	A/S			
Sediment buildup in riser?	A			
Concrete/masonry condition (Cracks or displacement? Spalling?)	A			
Metal pipe in good condition?	A			
Control valve operation?	A			
Pond drain valve operation?	A			
Outfall channels function, not eroding?	A			
Other (describe)	A			

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
Sediment Forebays				
Sedimentation description				
Sediment cleanout needed (over 50 percent full)?	A/S			
Permanent Pool Areas (if applicable)				
Undesirable vegetation growth?	A/M			
Visible pollution?	A/M			
Shoreline erosion?	A/M			
Erosion at outfalls into pond?	A/M			
Headwalls and endwalls in good condition?	A/M			
Encroachment into pond or easement area by other activities?	A/M			
Evidence of sediment accumulation?	A			
Dry Pond Areas (if applicable)				
Vegetation adequate?	A/M			
Undesirable vegetation or woody plant growth?	A/M			
Excessive sedimentation?	A			
Hazards				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			

Inspector Comments: _____

Overall Condition of Facility: Acceptable Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: _____
 (date)

Inspected by: (signature) _____
Inspected by: (printed) _____